

18/11/21 to 12/11/26

o/c



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



From
The Regional Fire Officer Central Region,
State Disaster Response and Fire Services,
Telangana, Hyderabad.

To,
M PADMARAJU,
gokaraju rangaraju educational society ganges valley
school sy.no.298,

Rc. No.417030002021 Dated:18/11/2021

Sir,
Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE
DEPARTMENT —Kukatpally Division.
Issue of No Objection Certificate for Occupancy to the Non Multi
storeyed Building of **gokaraju rangaraju educational society ganges valley school a and b blocks,sy.no.298** /-
Bachupally/Bachupally/Medchal, Hyderabad – Regarding.



Ref:


1. Acknowledgement No.417030002021 dt.18/11/2021
2. This Office Provisional NOC Ack No./RC No.1219/a1/2011 dt.15/09/2011
3. Inspection Committee Report, Ack No. 417030002021, dt. 18/11/2021

1. The Non Multi Storeyed Building Inspection committee, vide reference cited (3) have inspected the Non Multi Storeyed Building of **gokaraju rangaraju educational society ganges valley school a and b blocks,sy.no.298** /- **Bachupally/Bachupally/Medchal** and submitted the following report.

2. The builder was issued Provisional No Objection certificate vide reference cited (2) for construction of Non Multi Storeyed Building **Ground, 4 Floors**, with for Occupancy (). Now the builder has constructed Non Multi Storeyed Building with **Ground, 4 Floors**, with a height of **14.95 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy () and requested for No Objection Certificate for Occupancy.

3. Open Spaces : The builder provided the following open spaces all around the building.

| Sl.No | side | Open space Required as per Provisional No Objection Certificate | Open space Provided |
|-------|-----------------|---|---------------------|
| 1 | North | 6.00 | 6.00 |
| 2 | South | 6.00 | 6.00 |
| 3 | East | 6.00 | 6.00 |
| 4 | West | 6.00 | 6.00 |
| 5 | Front Direction | East | |



[Signature]

PRINCIPAL

**Ganges Valley School
Bachupally, Kukatpally,
Hyderabad-500 090.**

4. Means of Access :

| Sl. No | Gate Width As per NBC 2016 | Required | Provided |
|--------|----------------------------|----------|----------|
| 1 | Entry gate width | 4.50 | 6 |
| 2 | Exit Gate Width | 4.50 | 6 |
| 3 | Entry Gate Head Clearance | 5.00 | 4.5 |
| 4 | Exit Gate Head Clearance | 5.00 | 4.50 |

5. Travel Distance

| Sl. No. | Item / Description | Required (Not More than in Mtrs.) | Provided |
|---------|---|-----------------------------------|----------|
| 1 | Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit. | 30.00 | 30.00 |
| 2 | The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies) | 6.00 | 6.00 |

6. Stair Cases (As per NBC 2016)

| Sl.no. | Type of staircases | Width (In Mtrs) | No of staircases | Floors from | Floors to |
|--------|---------------------|-----------------|------------------|-------------|-----------|
| 1 | Internal staircases | 2.00 | 4 | Ground | Terrace |

the date of issue of this letter.

evacuate the area completely
at once from the nearest safe
exit.

Not, take all steps to isolate the area by
closing doors and windows.


This No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
Regional Fire Officer Central Region,
State Disaster Response & Fire Services,
Telangana, Hyderabad.

Copies to:

- i) The Management
- ii) Non Multistoried Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services.

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"



PRINCIPAL
Ganges Valley School
Bachupally, Kukatpally,
Hyderabad-500 090.

